

**PRO-ADVANCE TECHNOLOGY CO., LTD.**

9F., No.83, Sec. 3, Dusing Rd., Banciao City, Taipei County 220,  
Taiwan (R.O.C)

REPORT NO. : RI/2004/60016

PAGE NO. : 1 之 1

DATE : 2004/6/28

THE FOLLOWING MERCHANDISE WAS(WERE) SUBMITTED AND IDENTIFIED BY THE CLIENT AS :

<b>PRODUCT NAME</b>	PHYSICAL WATER CONDITIONER
<b>SAMPLE SUBMITTED</b>	PRO-ADVANCE TECHNOLOGY CO., LTD.
<b>PRODUCT DESCRIPTION</b>	1.KILL BACTERIUM 2. PREVENT SCALE
<b>STYLE/ITEM NO.</b>	HYDROFLOW, AQUAKLEAR, SPAKLEAR, STEAMKLEAR
<b>MANUFACTURER</b>	HYDROPATH (UK)LTD
<b>COUNTRY OF ORIGIN</b>	UK
<b>SAMPLE RECEIVED</b>	2004/6/11
<b>TESTING DATE</b>	2004/6/11

**TEST ITEM / METHOD**


Reference To AATCC 100 : 1. *Staphylococcus aureus* AACC 6538  
2. *Escherichia coli* AACC 8739

**TEST RESULT:**

TREATMEANT (REACTION TIME : 1 HR)

TEST BACTERIA	Counts (Before Circulation ) (CFU/ml)	Counts (After Circulation for 1 hour) (CFU/ml)	Reduction(%)
<i>Staphylococcus aureus</i>	1.2×10 <sup>5</sup>	<1	99.99
<i>Escherichia coli</i>	1.3×10 <sup>5</sup>	<1	99.99

THE REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF THE LABORATORY.



*Jeremy Li*  
Jeremy Li, M.R./Supervisor, Food Dept.  
Signed for and on behalf of  
SGS TAIWAN Ltd.